



Dublin City Council
Environment & Engineering Department, Drainage Division

Permit for the use of Bacterial additive within DCC area

Company name	NCH Ireland Ltd
Product Name	BioAmp
Permit #	PC0030906NCH
Permit Valid up to	31/12/2012

The above product was tested in field trials and the results were found to be satisfactory.


It is now deemed suitable for use in grease management in food service establishments subject to the manufacturers recommendations concerning dosing and application.

This permit is valid until 31st December 2012 and shall be subject to review at that time.

This permit is valid under the following conditions:

- Passive Grease Traps must be designed, installed and maintained in accordance with the NSAI standards I.S.EN 1825 parts 1 & 2 pertaining to grease separators
- The use of the bacterial product does not eliminate the requirement for regular pump-outs of the grease trap. All grease traps shall be required to be pumped out in accordance with the "25% rule". Where discrepancies occur DCC or their agents will have the final say in relation to pump-outs.
- The product manufacturer shall provide DCC with a list of premises where the product is being used.
- Where possible, the permit number should be displayed on the product.
- DCC shall be notified of any changes in the product specification.
- Each premises shall keep a copy of the attached "letter of approval" available on file for inspection.

Signed:


M. O'Dwyer
A/Executive Engineer

Date: 2/2/2012